



AURANGABAD MUNICIPAL CORPORATION
FIRE BRIGADE
TELEPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE / 459 /2022

Date 06 / 08 /2022

To,
Shri. Sanjay Bhattu Patil,
Swami Vivekananda Public School,
Gut No. 24, Plot No. 273, Sharnapur,
Dist. Aurangabad.

Sub:- Final Fire NOC is issued to the Swami Vivekananda Public School,
Gut No. 24, Plot No. 273, Sharnapur, Dist. Aurangabad.

Ref:- 1) Your letter dated 24/04/2017 2) Provisional Noc on date 04/09/2018.
3) Your Letter dated 06/08/2022 4) CFO Inspection on date 06/08/2022

With Reference to the above subject Final Fire NOC is issued Swami Vivekananda Public School, Gut No. 24, Plot No. 273, Sharnapur, Dist. Aurangabad. Plot area is 8800.00 sq.mtr.

Sr. No	Name of Building	Height of Building	Bild No.	Floors	Total Area of Plot	Total Buildup area	Final Noc Fees	Total Rs
1	Swami Vivekananda Public School	08.10 mtr.	1	Ground + 1 Floors	10000.00 Sq. mtr	2594.00 Sq. mtr	10000	10,000/-

Following Fire prevention and Fire protection & Fire Fighting measures subject to **School Building** is provided.

1. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 10000 lit capacity with the Booster pump-5 HP-01 No. of suitable capacity for building is provided.
3. 01 No. Fire service inlet 2 way incoming is provided.
4. 03 Nos. Yard Hydrant points all around the building with fire Hose pipe-03 Nos./ Branch-03 Nos is provided.
5. 02 No. Wet Riser having outlet on all floors with is provided.
6. 02 Nos. Hose reel of 100 feet on all outlets is provided.
7. Fire Extinguisher of ABC-06 Kg-06 Nos of suitable capacity / quantity is provided.
8. Main Staircase 1.50 Mtr Width is provided.
- 9 All the above requirements shall be carried out with prior approval from fire Brigade.
- 10 This Certificate shall be treated valid for a period of one year from the date fo issue from Fire Noc